

MARYLAND DEPARTMENT of the ENVIRONMENT
1800 WASHINGTON BOULEVARD
BALTIMORE, MARYLAND, 21230
(410) 537-3000
1-800-633-6101 (within Maryland)
http://www.mde.state.md.us



State of Maryland
Department of the Environment
Emergency Response Division
1800 Washington Blvd. Suite #105
Baltimore, Maryland. 21230-1721



24 HOUR SPILL REPORTING
(Toll Free) 1-866-633-4686
EMERGENCY RESPONSE OFFICE
(410) 537-3975
RESPONSE OFFICE FACSIMILE
(410) 537-3932

PURSUANT TO THE PROVISIONS OF STATE LAW AND REGULATION; (COMAR 26.10.01.03) "A PERSON DISCHARGING OR PERMITTING THE DISCHARGE OF OIL, OR WHO EITHER ACTIVELY OR PASSIVELY PARTICIPATES IN THE DISCHARGE OR SPILLING OF OIL, EITHER FROM A LAND BASED INSTALLATION, INCLUDING VEHICLES IN TRANSIT, OR FROM ANY VESSEL SHIP OR BOAT OF ANY KIND, SHALL REPORT THE INCIDENT IMMEDIATELY TO THE ADMINISTRATION." " THE REPORT OF AN OIL SPILL OR DISCHARGE SHALL BE MADE TO THE ADMINISTRATION IMMEDIATELY, BUT NOT LATER THAN TWO HOURS AFTER DETECTION OF THE SPILL." *** FIRE DEPARTMENT PERSONNEL . SEE REVERSE ***

ADC Map Coord _____ Date of spill: Mo. 1 2 / Day 0 9 / Yr. 20 2 0 Time of spill: 1 5 4 5 Hours (24 hour clock)
Fire Department Report No.: _____ Police Department Report No.: _____

Location of spill - Street address: _____
8537 Paint Branch Drive, Bldg. 424
City / Town College Park
MD County Prince George's
Zip 20742

Product Name: _____
Ultra Low Sulfur Diesel Fuel
(Indicate Gasoline, Diesel, Heating Oil, Chemical Name or UN ID etc.)
Container Type: _____
AST / Fuel Dispenser
(Indicate AST, UST, Transformer, Saddle Tank, Drum etc.)

Capacity of Vessel, Vehicle or Tank: _____
20,000 Gallons
Amount IN Vessel, Vehicle or Tank: _____
Gallons
Estimated Amount Spilled: _____
200 Gallons

Transportation Incident: _____
(Indicate Type of Auto, Truck, Train, Aircraft or Watercraft etc.)
Fixed Facility Incident: _____
Institutional (university) - shuttle bus maintenance facility
(Indicate Type of Industrial, Commercial, Residential etc.)

Contained on Land
 Entered Storm Drain or Ditch
 Entered Sanitary Sewer
 Is Below Ground
 Entered surface waters:
Waterway Name _____

Vehicle Tag Number and State: _____
N/A
DOT or ICC MC Number: _____
N/A
Hull Numbers and Name: _____
N/A

Person(s) Responsible for Spill: (Driver if Vehicle)
Name: Edwin Brown (facility maintenance manager - evening shift)
Address: 8537 Paint Branch Drive, Bldg. 424
City/State: College Park, MD Zip: 20742
Phone: (301) 314-8631
Drivers Lic.No. N/A State: _____

Be Sure to Complete Both Sections
Don't Forget to Sign Below

Company Responsible for Spill: (N/A if private citizen.)
Name: University of Maryland
Address: 1101 Main Administration Building
7901 Regents Drive
City/State: College Park, MD Zip: 20742
Phone: 301-405-3960
Fed. Employer ID No. 52-06002033

Cause of Spill:
 Motor Vehicle Accident
 Personnel Error/Vandalism
 Tank/Container/Pipe Leak
 Mechanical Failure
 Transfer Accident

Identify All Groups that Participated in Spill Mitigation : Responsible Party
 MDE ERD # _____ # _____
 Federal : _____
 State : _____
 Local : _____
 Contractor: Triumvirate Environmental

Materials used by You to contain/clean-up spill:
Sorbent Dust: 5 Bags
Sorbent Pads: 10 each or bales
Sorbent Booms: 3 each or bales
Sorbent Sweeps: _____ each or bales
Overpack Drums : 1 ea. Steel or Poly
Other: _____

Responsible Party : Describe circumstances contributing to the spill. (Additional space on back) [Optional for FD or Gov't Personnel]

A nozzle on the fuel dispenser failed to shut off and resulted in an overflow of diesel fuel during the refueling of one of the buses at the facility.
All fuel was contained on the containment pad at the fueling facility.

MDE was notified of the spill by phone at approximately 5:30 pm, once the situation had been assessed and cleanup operations had been initiated.
Responsible Party : Describe Containment, Removal and Clean-up operations, including disposal. (Additional space on back) [Optional for FD or Gov't Personnel]

The Office of Environmental Affairs responded for the University. Absorbent materials were used to remove the fuel on the ground surface. All liquid was contained to the containment pad at the fueling facility. A vacuum truck was used to pump water and fuel from the containment sump in the middle of the fueling facility. No fuel entered the environment. All fuel spilled was contained and cleaned up.
Responsible Party : Procedures, Methods and Precautions instituted to prevent recurrence of the spill. (Additional space on back) [Optional for FD or Gov't Personnel]

We will contact a contractor to service the fuel dispenser and ensure that it is operating properly.

THE UNDERSIGNED CERTIFIES THAT THE INFORMATION PROVIDED IS TRUE AND CORRECT TO THE BEST OF HIS OR HER KNOWLEDGE AT THE TIME THE REPORT WAS COMPLETED.
Print Name: Jason Baer Company or Fire Department: University of Maryland
Address : 4716 Pontiac Street, #0103 (Seneca Building) City / State / Zip College Park, MD 20742
Telephone 202-441-6391 (cell) Signature Jason Baer